



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION VIII

999 18th STREET - SUITE 500
DENVER, COLORADO 80202-2466

February 9, 2004

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Kevin Brown, Director
Division of Drinking Water
Utah Department of
Environmental Quality
150 North 1950 West
Salt Lake City, Utah 84114-4830

Re: Closure of Notice of Violation
Angell Springs
Docket #SDWA 8-99-31
PWS ID #UT4914019

Dear Mr. Brown:

This letter is to inform you of the Environmental Protection Agency's (EPA) decision to close the Notice of Violation issued May 25, 1999 and to not pursue further enforcement action against Angell Springs, Docket Number SDWA 8-99-31. This decision is based upon EPA's understanding that the system now utilizes continuous disinfection and improvements have been completed by the Utah Department of Transportation to protect the spring and therefore ensure compliance with the total coliform maximum contaminant level.

If you have any questions about this decision please call Jackson Naftel of my staff at (303) 312-6362.

Sincerely,

SIGNED

Lisa Kahn, Team Leader
Drinking Water Enforcement Program
Office of Enforcement, Compliance and
Environmental Justice

cc: Deborah Beaver, Angell Springs
Ken Bousfield, UTDEQ

THIS DOCUMENT WAS FILED IN THE REGIONAL HEARING CLERK'S OFFICE ON
FEBRUARY 10, 2004.

cc: Deborah Beaver, Angell Springs
Ken Bousfield, UTDEQ